

1    Q.    **Project C-44: Increase Fuel Storage – Rigolet**

2           Does Hydro have any estimate regarding the cost to install the portable 90,800 litre  
3           self-dyking fuel tank to meet the fuel storage needs for the winter 2014-2015?

4

5

6    A.    Hydro has recently concluded that the purchase and installation of a 90,800 litre  
7           self-dyking fuel tank will no longer be required for the winter of 2014/2015. Please  
8           refer to the response to IC-NLH-038 for more details.