

-
- 1 Q. **Reference: Upgrade Powerhouse Roofing – Holyrood, Volume I, Tab 4**
- 2 Please reconcile the statement at page i of Volume I, Tab 4 “*The upgrades, outlined*
- 3 *in this proposal, include the replacement of roofing areas deemed to have a*
- 4 *remaining service life of less than **two** years.”* with the statement at C-11 “*Upgrades*
- 5 *consist of the replacement of all Holyrood Powerhouse roofing areas deemed to*
- 6 *have a remaining service life of less than **five** years.”* (emphasis added)
- 7
- 8
- 9 A. As noted on pages 1 and 2 of the report, this project comprises the first year of a
- 10 three year program for the completion of roof upgrades at the Holyrood
- 11 Powerhouse. This three-year program will focus on the completion of upgrades to
- 12 all roof areas identified in the Level 2 condition assessment as having a service life
- 13 of less than five years. The roof areas to be upgraded in 2015 have been deemed to
- 14 have a service life of less than two years.