

- 1 Q. Reference: Refurbish Generation Unit – Snook’s Arm, Volume I, Section D,
2 Page D-57
3 *“There is also a decommissioned RTU cabinet and two side panels.”*
4 Is the Snook’s Arm hydro plant remotely controlled from Hydro’s Energy Control
5 Centre?
6
7
8 A. The Snook’s Arm Unit is not remotely controlled from Hydro’s Energy Control
9 Center.