

1 Q. Reference: Refurbish Generation Unit – Snook’s Arm, Volume I, Section D,
2 Page D-57

3 *“There is also a decommissioned RTU cabinet and two side panels.”*

4 How many operators are responsible for the operation and maintenance of the
5 Snook’s Arm and Venam’s Bight hydro plants? Where are these operators
6 stationed?

7
8
9 A. One primary contract operator is responsible for both the Snook’s Arm and
10 Venam’s Bight plants. This operator lives in the nearby town of La Scie and is
11 dedicated to these two plants. This operator has a substitute in place to perform
12 operator duties when the primary operator is not able to visit the plants. The
13 operator visits each site twice a week and responds to alarms received at ECC. This
14 operator also performs reservoir surveillance and minor running maintenance and
15 is on-site when maintenance crews are present. Maintenance for these units is
16 performed by the Hydro Generation maintenance staff located in Bay d’Espoir.