

1 Q. Reference: Refurbish Generation Unit – Snook’s Arm, Volume I, Section D,
2 Page D-60

3 *“In the past years, from 2007 to 2014, the Snook’s Arm unit has been off line due*
4 *to needed runner repairs, an alignment problem, and failure of the Giljet*
5 *assembly.”*

6 Provide the unit availability by year for the period from 2004 to 2013.

7

8

9 A. Unit availability is not recorded for this site. The best indication of unit availability
10 can be identified in the production metering information identified in the table
11 below. Note that in addition to unit availability, this information is also affected by
12 reservoir levels.

**SNOOK'S ARM
MONTHLY GENERATION**

<u>Year</u>	<u>JAN</u>	<u>FEB</u>	<u>MAR</u>	<u>APR</u>	<u>MAY</u>	<u>JUN</u>	<u>JUL</u>	<u>AUG</u>	<u>SEPT</u>	<u>OCT</u>	<u>NOV</u>	<u>DEC</u>
	KWh	KWh	KWh	KWh	KWh	KWh	KWh	KWh	KWh	KWh	KWh	KWh
2004	250,920	149,760	137,880	292,140	408,600	385,380	313,110	275,310	236,070	387,630	360,900	377,910
2005	377,550	252,090	283,320	336,780	372,780	379,080	252,000	264,600	148,950	327,780	351,090	254,700
2006	386,280	307,260	188,190	348,930	394,020	380,070	389,430	169,560	0	0	0	138,690
2007	258,660	0	211,590	147,600	429,300	405,270	353,430	341,100	384,930	408,420	357,480	369,000
2008	286,470	237,510	264,780	299,160	430,470	411,930	387,810	240,840	40,770	195,210	152,280	262,980
2009	246,420	168,750	169,470	341,460	426,240	350,820	409,500	215,640	278,100	351,360	66,060	0
2010	0	0	0	0	0	0	0	0	0	0	0	234,810
2011	362,970	320,940	373,320	351,720	368,910	356,850	372,240	368,640	349,830	318,780	353,790	325,260
2012	282,780	206,460	230,760	287,910	366,570	342,000	261,360	197,550	314,730	308,160	357,390	369,540
2013	300,060	257,850	365,940	330,390	360,270	347,400	223,830	185,040	151,470	287,280	291,510	354,510