

1 Q. Reference: Refurbish Generation Unit – Snook’s Arm, Volume I, Section D,
2 Pages D-60 and D-61

3 *“The five-year maintenance history for the Snook’s Arm Generating Unit is shown*
4 *in table 2.”*

5 What costs are included in this maintenance history?
6
7

8 A. The costs included in this maintenance history include: labour and material for
9 performing annual preventative maintenance; and labour and material for
10 performing corrective work performed on the hydraulic turbine/generator unit by
11 maintenance crews. It excludes the operator contract (operation and running
12 maintenance) costs as well as any penstock, reservoir, unit auxiliaries, or property
13 maintenance. Capital costs are also excluded.