

1 Q. Reference: Replace Accommodations and Septic System, Volume II, Tab 20,

2 Page 10

3 *“The installation of new modular housing units constructed using improved*  
4 *insulating components and a modern building envelope will provide a significantly*  
5 *improved dynamic thermal performance and, consequently, result in energy*  
6 *savings.”*

7 How is energy provided at the Ebbeginbaeg site?

8

9

10 A. The Ebbeginbaeg site is fed from the Island Interconnected System. Power to the  
11 site is provided by a 25 kV distribution line which originates from the Upper Salmon  
12 Terminal Station.