

1 Q. Reference: Construct Second Distribution Feeder Nain, Volume II, Tab 25,
2 Page 29
3 *“Although a voltage regulator is a technically viable alternative to eliminate the*
4 *low voltage issue in Nain, it would not be a practical option. In the event of a*
5 *regulator failure, the necessary heavy equipment to perform a voltage regulator*
6 *replacement is not available in Nain. As well, access by sea may not be available*
7 *for up to nine months depending on ice conditions. As a result, this alternative*
8 *was not considered and was screened out prior to the economic analysis.”*

9 What is Hydro’s best estimate of (i) the cost of installation of the necessary voltage
10 regulators in Nain, (ii) the cost of provision of a spare regulator stationed in Nain
11 and (iii) the cost of the necessary heavy equipment to replace a voltage regulator?
12
13

14 A. (i) The cost to purchase and install the necessary voltage regulator arrangement in
15 Nain is estimated to be approximately \$744,500, including interest, escalation and
16 contingency.
17

18 (ii) The cost of a provision for a spare regulator stationed in Nain is estimated to be
19 approximately \$71,100.
20

21 (iii) The cost for the necessary heavy equipment to lift a 5,200 lb voltage regulator
22 is approximately estimated to be \$200,000 (plus shipping). It should be noted that
23 the appropriate equipment can be rented in Nain at \$1,200 per day. However, this
24 equipment is not guaranteed to be in Nain for the expected life of the regulators.
25 Hydro requires a guaranteed method of replacing a regulator. In the event that this
26 lifting equipment is not available it must be shipped in from Happy Valley-Goose
27 Bay. This may not be possible during the winter season when there is no boat

1 access into Nain due to sea ice build-up. The time frame of this inaccessibility into
2 Nain could last up to nine months.

3
4 The estimated total capital cost of installing a bank of voltage regulators in Nain,
5 including a spare and the equipment to replace a voltage regulator, is estimated to
6 be \$1,015,600 which is marginally less than constructing a second feeder
7 (\$1,050,300). However, the lifecycle costs associated with voltage regulators would
8 be higher than for a second feeder due to power losses¹. Power losses associated
9 with regulators can be significant, especially for a system whose generating source
10 is a diesel plant. Hydro anticipates that the cost in losses would be approximately
11 \$15,000/year² for a three phase bank of 400A voltage regulators in Nain.

12
13 The construction of a second feeder would not only support future load growth but
14 would provide improved reliability to the Nain system. With a unit out of service
15 following an outage in Nain during peak conditions, the diesel plant may be
16 incapable of re-energizing the entire system all at once. Although this is a rare
17 occurrence, currently the only way to mitigate this problem and accommodate cold
18 load pick-up is to sectionalize the distribution system. This can be challenging and
19 costly because a line-crew is required. It should also be noted that Hydro does not
20 have a line-crew stationed in Nain and therefore one must be transported from one
21 of Hydro's other locations. This can be time consuming and therefore can prolong a
22 system outage. Although each diesel plant has a DSR or diesel plant operator, they
23 are not trained to perform line work.

24
25 A second feeder would allow a DSR to sectionalize the system directly from the
26 diesel plant and avoid any switching on the distribution system. The DSR and the

¹ Load and no-load losses

² Assuming a plant efficiency of 3.60 kWh/L and a fuel cost of \$1.107/L

1 diesel units would have the capability of restoring one feeder at a time in the event
2 of an outage. This would lessen the strain on the diesel units when picking up the
3 load after an extended outage and avoid the need for a line crew. This would avoid
4 the situation that occurred during December 2012, when, with a unit out of service,
5 Hydro couldn't reenergize the town distribution system without first bringing in a
6 line crew from Happy Valley to perform switching on the distribution system.

7

8 A second feeder would also improve flexibility as it pertains to performing
9 maintenance. It would reduce the need for planned outages to perform corrective
10 and preventative maintenance. With a two feeder system, sections of the
11 distribution system could be easily isolated with minimal power interruptions to the
12 customers.