

1 Q. Reference: Install Automated Meter Reading, Volume II, Tab 26, Page 4
2 *"The AMR system being deployed is Landis + Gyr's PLX System. The PLX System is*
3 *a two-way power line carrier based communications system."*

4 Does Hydro plan to use the two-way communication capabilities of the PLX System
5 to do anything other than monthly meter reading? If so will the implementation of
6 this additional functionality be the subject of a future capital budget submission?

7
8
9 A. Except for the remote software upgrading capability, there is no plan at this time to
10 use the two-way communication capabilities of the PLX System to do anything else
11 other than monthly meter reading. Any plan to pursue additional functionality
12 would be identified in a future capital budget submission.