

1 Q. Reference: Install Automated Meter Reading, Volume II, Tab 26, Page 4
2 *“The AMR system being deployed is Landis + Gyr’s PLX System. The PLX System is*
3 *a two-way power line carrier based communications system.”*

4 The previous technology deployed by Hydro was the TS1 System. Does Hydro plan
5 to replace the installed TS1 technology with the PLX System in the near future?
6

7
8 A. There is no plan or identified need to replace any of the installed TS1 systems with a
9 PLX system at this time. Any such plan would be identified in a future capital
10 budget submission.