

1 Q. **Reference: Upgrade Circuit Breakers, Volume II, Tab 13, Table 3, Page 16**

2 The referenced table indicates that breakers were purchased in 2012 and 2013, and
3 not installed. Have these breakers been installed since the year of purchase? If so,
4 please provide details regarding their installation. If not, please indicate why they
5 have not been installed.

6

7

8 A. The breaker referenced in Table 3 that was purchased in 2012 was for breaker
9 B1L36 at Hardwoods and it was installed in 2013. The breaker referenced in Table 3
10 that was purchased in 2013 was for Cow Head (CHD) breaker B1L27 and it is
11 scheduled to be replaced starting November 4, 2014.