

1 Q. In response to PUB-NLH-11 filed with the 2014 Capital Budget Application Hydro
2 states: *“Hydro will address the recommendation to remove the existing CP system*
3 *and all associated components as part of the scope of work for a separate capital*
4 *project which is in the capital plan for 2015 under the heading “Refurbish Surge*
5 *Tanks – Bay d’Espoir.”*

6 Please provide an update regarding the removal of the Cathodic Protection System
7 and associated components for Surge Tank 3.

8

9

10 A. In line with Hydro’s response to PUB-NLH-011 filed with the 2014 Capital Budget
11 Application, the removal of the existing Cathodic Protection (CP) system and
12 associated components is part of the scope of work of the 2015 Capital Budget
13 project to install a protective coating on the interior of the Surge Tank #3.

14

15 Removal costs do not affect the capital funds requested in this project. The funds to
16 remove the CP system will be included in Hydro’s 2015 operating.