

1 Q. **C-48; Volume II, Tab 20: Replace Accommodations and Septic System –**
2 **Ebbegunbaeg**

3 How often are Hydro employees required to perform work at Ebbegunbaeg and
4 what is the typical duration of their stay on site?

5

6

7 A. The typical duration of stay at the Ebbegunbaeg water control structure depends on
8 the nature of the work.

9

10 Water system attendants visit Ebbegunbaeg bi-weekly via helicopter during the
11 Burnt Dam crew change to perform dam/dyke surveillance. This visit is typically one
12 to two hours in duration.

13

14 Maintenance crews typically stay at Ebbegunbaeg to perform planned maintenance
15 two to four times a year with a typical stay of between four and eight days.

16

17 Maintenance crews typically visit Ebbegunbaeg between one and four times a year
18 to perform unplanned/emergency maintenance. The duration of stay for this type
19 of work ranges between a few hours and four days.