

1 Q. **C-57; Volume II, Tab 24: Install Transformer On Line Gas Monitoring – Various**  
2 **Sites**

3 Does Hydro intend to continue sampling for dissolved gas analysis after the on line  
4 gas monitoring systems have been installed on transformers?

5

6

7 A. Yes, Hydro still plans to continue its sampling for dissolved gas analysis after the on  
8 line gas monitoring systems have been installed. The monitoring systems will act as  
9 an additional tool to support routine sampling and the gas relay protection that is  
10 currently installed on Hydro's Power Transformers.