

1 **Q.** *Schedule B 2015 Capital Projects (p. 45 of 97)*

2
3 **Newfoundland Power outlines that it uses a 7-year inspection cycle for distribution**
4 **feeders. Is the 7-year inspection cycle for distribution feeders an industry wide**
5 **practice?**
6

7 A. Newfoundland Power is not aware of an industry wide practice with respect to inspection
8 cycles for distribution feeders.