

1 **Q. *Tab 1.1 2015 Facility Rehabilitation – Hydro Dam and Spillway Rehabilitation***

2
3 **How long has the mechanical lift at the Horse Chops Spillway not been functioning**
4 **as designed?**

5
6 A. Operational difficulties with the mechanical lift at Horse Chops Spillway were first noted
7 in dam safety inspections in 2007. The mechanical lift has not functioned as designed
8 since that time.