

1 **Q.** *Tab 1.1 2015 Facility Rehabilitation – Hydro Dam and Spillway Rehabilitation –*
2 *Frank’s Canal Spillway (p. 5)*

3
4 **What is the expected life of the new timber-structure proposed for Frank’s Canal**
5 **Spillway?**

6
7 **A.** The expected life of the new timber structure is 25 years.