

1 **Q. Tab 4.2 Feeder Additions for the Load Growth**

2
3 **How long has MOB-01 been in overload condition?**

4
5 A. As indicated in 4.2 *Feeder Additions for Load Growth*, at pages 2 and 3, there are two
6 sections of distribution feeder MOB-01 where the peak load has exceeded the planning
7 rating of the conductor.¹ The first section consists of #4/0 AASC conductor with a
8 planning rating of 7.7 MVA. The second section consists of #4 CU conductor with a
9 planning rating of 3.3 MVA.²

10
11 Both sections of the feeder initially exceeded their planning ratings in February 2013.
12 They exceeded their planning ratings again during the winter months of 2014.

¹ The planning rating is theoretically 75% of the winter conductor ampacity and is based on ambient conditions of 0°C and 2ft/s wind speed. For additional explanation of Newfoundland Power conductor ratings, see the response to Request for Information PUB-NP-146 from the Investigation and Hearing into Supply Issues and Power Outages on the Island Interconnected System.

² The planning ratings for both 4/0 AASC and #4 CU conductor on a 12.5 kV line are shown in Appendix A to the report 4.2 *Feeder Additions for Load Growth*.