

- 1 **Q. If available, please provide the total Incapability Factor (ICbF - %) for the Pierre's**
2 **Brook hydro plant, by year, from 2005 to 2014 Target.**
3
4 A. Newfoundland Power does not calculate Incapability Factor (“ICbF”) for its hydro
5 plants.¹

¹ ICbF (%) is the ratio of total equivalent outage time, in hours, to number of unit hours multiplied by 100. Like DAFOR, ICbF is an equipment reliability statistic in the CEA database for hydro plants with outputs greater than 5 MW. Newfoundland Power is not a CEA participant in the collection of this data as explained in the response to Request for Information NLH-NP-002.