

Replacement of the Lower Reheater Boiler Tubes on Units 1 & 2 at HTGS

1 Q. Page 7, lines 5-7: Please provide the expected maximum loading of Units 1 and 2
 2 when placed back in service following replacement of the lower reheater tubes.

3
 4

5 A. Currently the reheaters are the load limiting components of Units 1 and 2 with a
 6 maximum output of 120MW. Once these lower tube replacements are complete,
 7 the reheaters will be restored to a higher unit loading. Hydro has conducted a
 8 review of the boilers and unit condition in general, to establish an appropriate
 9 maximum load for each Holyrood unit to support reliable operation going forward.
 10 Below are the preliminary results of this review. Hydro notes that the results below
 11 are being reviewed by an external consultant to determine if the ratings are
 12 appropriate or if additional changes in unit ratings are required. This review is not
 13 yet complete and Hydro will update the Board as to any additional changes.

14

	U1	U2	U3
Normal Maximum Operating Load	140	140	130
Emergency Maximum Operating Load	150	150	140