

1 Q. Page 8, Table 2: Please provide the initial Holyrood CT forecasted operating  
2 requirements by month for 2015-2017.

3

4 A. Please see PUB-NLH-001, Attachment 1 which provides the initial Holyrood CT  
5 forecasted operating requirements by month for 2015-2017. The methodology  
6 outlined in Section 2.2 of Hydro's application, to determine the annual expected  
7 number of starts for 2015-2017, also applies for the determination of the monthly  
8 starting requirements.

9

10 Please note that any differences in the annual quantities in this table, when  
11 compared to Table 2 of the application, are due to rounding.

## Initial Holyrood CT Forecast Requirements 2015-2017 (by Month)

Year	Month	Operating Hours	Equivalent Hours (EBH)	Starts	Equivalent Starts (ES)
<b>2015</b>	Jan	39	50.7	13	16.9
	Feb	39	50.7	13	16.9
	Mar	39	50.7	13	16.9
	Apr	1	1.3	1	1.3
	May	1	1.3	1	1.3
	Jun	1	1.3	1	1.3
	Jul	1	1.3	1	1.3
	Aug	1	1.3	1	1.3
	Sep	1	1.3	1	1.3
	Oct	1	1.3	1	1.3
	Nov	1	1.3	1	1.3
	Dec	62	80.6	19	24.7
	<b>Annual Totals</b>		187	243.1	66
<b>2016</b>	Jan	62	80.6	19	24.7
	Feb	62	80.6	19	24.7
	Mar	62	80.6	19	24.7
	Apr	1	1.3	1	1.3
	May	1	1.3	1	1.3
	Jun	1	1.3	1	1.3
	Jul	1	1.3	1	1.3
	Aug	1	1.3	1	1.3
	Sep	1	1.3	1	1.3
	Oct	1	1.3	1	1.3
	Nov	1	1.3	1	1.3
	Dec	102	132.6	29	37.7
	<b>Annual Totals</b>		296	384.8	94
<b>2017</b>	Jan	102	132.6	29	37.7
	Feb	102	132.6	29	37.7
	Mar	102	132.6	29	37.7
	Apr	1	1.3	1	1.3
	May	1	1.3	1	1.3
	Jun	1	1.3	1	1.3
	Jul	1	1.3	1	1.3
	Aug	1	1.3	1	1.3
	Sep	1	1.3	1	1.3
	Oct	1	1.3	1	1.3
	Nov	1	1.3	1	1.3
	Dec	130	169.0	36	46.8
	<b>Annual Totals</b>		444	577.2	131