

1 Q. Please confirm the average forced outage rates for the Holyrood thermal units and
2 Hydro's hydraulic units used for the July 2016 – April 2017 Holyrood CT Operating
3 Forecast presented in Table 5 on page 11.

4

5

6 A. To develop the forecast requirements for the remainder of 2016, Hydro assumed
7 that Holyrood Units 1 and 2 would continue to operate at a derating to 120 MW
8 (when required to be on line) up to the time of their respective annual maintenance
9 outages. Unit 3 was assumed to operate at a maximum loading of 150 MW through
10 to the remainder of the year. Following the annual maintenance outages it was
11 assumed that Holyrood Units 1 and 2 would be restored to a maximum output of
12 160 MW per unit. There were no other Holyrood unit deratings or forced outage
13 times reflected in the Holyrood CT forecast for the remainder of 2016.

14

15 For 2017 it was assumed that Units 1, 2 and 3 would continue to be operable at
16 maximum ratings of 160 MW, 160 MW and 150 MW, respectively¹. There were no
17 other Holyrood unit deratings or forced outage times reflected in the Holyrood CT
18 forecast for 2017.

19

20 The average forced outage rate for Hydro's hydraulic units is assumed to be 0.9%
21 for the entire forecast period.

¹ At the time of drafting the Combustor Inspection and Overhaul of the Holyrood CT Capital Budget Supplemental, a more current forecast of the ratings on the Holyrood Thermal Units, taking into account the AMEC report findings as communicated to the Board on August 12, was not yet available. It is noted that the overall unit ratings are similar to the previous numbers used in the forecast and will not have material impact on the load forecast.