

1 Q. With reference to the criteria to be provided in response to IC-NLH-1 and IC-NLH-2,
2 has Hydro established benchmark or target future performance and reliability
3 criteria for the Hardwoods Gas Turbine and Stephenville Gas Turbine, for the period
4 from 2015 to their respective planned or anticipated decommissioning as a thermal
5 generation source?

6

7

8 A. With respect to the Hardwoods Gas Turbine and the Stephenville Gas Turbine,
9 Hydro has an annual UFOP target of 10.62% with a sensitivity of 20%. There are
10 currently no plans to change these targets for the period from 2015 to their
11 respective planned or anticipated decommissioning as a thermal generation source.