

1 Q. **Tab C – Projects \$500,000 and Over: p. C-43 – Replace Diesel Units, Cartwright and**
2 **Charlottetown**

3 Is there any recourse against the OEM of Unit 2079 installed in Charlottetown in
4 light of its premature failure?

5

6

7 A. Unit 2079 was purchased in 2006 and experienced its first failure in 2012. The
8 warranty period for a new diesel generator is one year, and therefore, there is no
9 recourse against the OEM.