

1 Q. CA-NLH-26 Volume III, Tab 11 – Additions for Load Growth – Isolated  
2 Generating Stations, L'Anse-au-Loup and Postville Diesel Plant

3 Please provide an update on the status of the 600 kw unit being replaced at L'Anse-  
4 au-Loup with a 1,825 kw scheduled to occur during the summer of 2015.

5

6

7 A. The new 1,825 kW diesel genset, which is replacing Unit 247 (600kW), will be  
8 commissioned by the end of September 2015. Unit 247 will then be  
9 decommissioned and disposed of, as it has reached the end of its useful service life.