
1 Q. **Volume III, Tab 11 – Additions for Load Growth – Isolated Generating Stations,**
2 **L'Anse-au-Loup and Postville Diesel Plant**

3 Does the temporary nature of some of the L'Anse-au-Loup larger customers (i.e. the
4 Valard construction camp is expected to have a service life of 2 years) reduce the
5 need for a new unit in the long term?
6
7

8 A. No, it does not reduce the need in the long term. The operating load forecast for
9 the L'Anse Au Loup system is summarized in Table 15 of the proposal report in
10 question. The L'Anse-au-Loup load forecast does not include any contributions
11 from temporary services. The only large temporary customer currently connected
12 to the L'Anse-au-Loup system is the Valard construction camp. The Valard
13 construction camp demand was not included in the peak load forecast because this
14 service has backup generation that would be utilized to offset its own demand
15 during system peak conditions.