

1 Q. **Volume III, Tab 27 – Replace Roof on Services Building, Bishop’s Falls**

2 At page 7 Hydro states that the added safety benefits provided by cold-applied  
3 systems make it a clear cut choice for Hydro. Is the open flame heat source for the  
4 installation of the traditional hot applied system the only safety benefit being  
5 referred to by Hydro? If not, please list the safety benefits of the cold applied roof  
6 Hydro is referring to.

7

8

9 A. The elimination of the open flame heat source, required for the installation of  
10 traditional hot applied roofing systems, provides for the safety of the installer and  
11 building occupants alike. It is the only safety benefit being referred to by Hydro.