

1 Q. **Volume III, Tab 27 – Replace Roof on Services Building, Bishop’s Falls**

2 What is the cost of the hot applied roof versus the current proposal?

3

4

5 A. Hydro has not completed a detailed estimate for the application of a hot applied
6 roofing system, on the Bishop’s Falls Services Building. Generally speaking, cold-

7 applied systems cost approximately 30% more to install than hot applied systems.