

1 **Q. Project C-12: Rewind Rotor and Install Flux Probe Unit 3 - Holyrood**

2 At page 8 of the Report at Tab 5, Vol II, it is stated that:

3 “The extra handling of the rotor would require additional costs and would
4 introduce risks to workers and equipment. Again, if the 2016 test results
5 indicated that the stator must be addressed before the planned major
6 overhaul in 2022, Hydro would undertake the required work at the required
7 time.”

8 Please provide the estimated cost of additional handling of the rotor as compared
9 to the suggested approach?

10

11

12 **A.** The estimated cost for the removal and reinstallation of the rotor for this unit is
13 approximately \$1,000,000. This work requires a Unit 3 outage of approximately
14 eight weeks.