

1 Q. **Project C-35: Construct 230 kv Transmission Line-Soldiers Pond to Hardwoods**

2 With reference to Maintenance History, at pages 12-13 of the Report at Tab 9, Vol.
3 II, maintenance history tables were provided for TL201, TL218 and TL242. Please
4 provide the maintenance history of TL266 for the years 2010 to 2015.

5

6

7 A. The 17 kilometre section of TL 201 between Soldiers Pond to Hardwoods Terminal
8 Stations will be relabelled as TL 266. The maintenance history for TL 266 for the
9 years 2010 – 2015 is listed below. The only cost within this time period is due to
10 insulator replacements in 2014.

YEAR	CAPITAL (WPLM)	CM
2014	\$140,824	-
2013	-	-
2012	-	-
2011	-	-
2010	-	-
TOTAL	\$140,824	-