

- 1 Q. **Project C-52: Perform Wood Pole Line Management Program**
- 2 Please identify the number of defective components identified to date in the year
- 3 2015 as part of the Wood Pole Management Program.
- 4
- 5
- 6 A. The table below summarizes the defective components identified as part of the
- 7 Wood Pole Line Management Program as of September 18, 2015, a total of 76
- 8 components. Inspections will continue until mid-November.

Component	No. Identified as Defective
Poles	25
Cross arms	7
Cross bracing	5
Knee braces	2
Insulators	4
Foundations	1
Miscellaneous	32