

1 Q. **Project D-27: Replace Powerhouse No. 1 Station Service Transformer - Bay**
2 **d’Espoir**

3 With reference to Volume I, Tab D, pages D-27 to D-30, when were the noted
4 distribution and padmount transformers installed at the Bay d’Espoir generating
5 plant?
6
7

8 A. This project is proposing that the existing station service transformers be replaced
9 with a three phase padmount transformer. The existing station service
10 transformers consist of two banks of 167 kVA pole top distribution transformers.
11 Each bank consists of three single phase transformers. The first bank of distribution
12 transformers was installed in 1988. The second bank was installed in 1991.