

1 Q. **Project D-298: Upgrade Aluminum Support Structure - Holyrood**

2 Provide an estimate of future maintenance costs projected with respect to the
3 aluminum support structures at the Holyrood Generating Station.

4

5

6 A. Outside of routine visual inspections, completed for all of Hydro's support
7 structures, no future maintenance costs are anticipated for the aluminum structure
8 component of the support structures at the Holyrood terminal station.