Q. Project E-2: Replace Generator Cooling Water Piping - Hinds Lake
With reference to the "Justification" for this Project, please provide details with

respect to the cost of piping, the cost of cleaning piping and Hydro's anticipated

future maintenance costs associated with the suggested 316 stainless steel

5 schedule ten pipe.

A. The cost of stainless steel piping replacement is detailed in Table 1 and there is no future capital costs required in its useful life of at least 40 years. The corrosion resistance of stainless steel increases its useful life and reduces adhering of the organic material to the internal pipe surface; therefore, there would be no cleaning costs associated with the new piping. The future maintenance costs associated with stainless steel piping would also be minimal as stainless steel does not require painting and it has high resistance to corrosion.

The cost of current piping cleaning is approximately \$47,000. The cleaning will not extend the useful life of the existing piping which is already near to the end of its useful life. Also, there are runs of pipe at Hinds Lake (approximately 25%) that will have to be replaced where removing of organic material is impossible. In addition, the piping cleaning does not provide a perfect internal pipe surface finish. In this case, the organic material will continue to adhere to the internal pipe surface more than the case when using new piping.

Page 2 of 2

Table 1: Budget Estimate

Project Cost: (\$ x1,000)	2016	2017	Beyond	Total
Material Supply	40.4	0.0	0.0	40.4
Labour	93.1	0.0	0.0	93.1
Consultant	0.0	0.0	0.0	0.0
Contract Work	0.0	0.0	0.0	0.0
Other Direct Costs	8.4	0.0	0.0	8.4
Interest and Escalation	11.4	0.0	0.0	11.4
Contingency	28.4	0.0	0.0	28.4
TOTAL	181.7	0.0	0.0	181.7

1