

1 Q. **Reference: Soldiers Pond to Hardwoods Corridor Upgrade, Volume II, Tab 9, Page**  
2 **16** Please provide a list and estimated cost of the critical spares to be provided in  
3 each of the alternatives for increasing the capacity in the SOP-HWD corridor.  
4  
5

6 A. The table below lists the critical spares cost for each alternative. Estimated cost is  
7 based on 10% of total material cost. Consideration was given for the TL 218  
8 reconfiguration but it was not considered a viable option based on the initial  
9 technical and economic review. Therefore, critical spares were not examined.  
10

Alternative	Critical Spares Cost
Thermal Upgrading of TL 266	\$124,656
New TL 266 Steel Tower Line	\$513,122
Reconfiguration of TL 218	N/A