

1 Q. Tab 3; Volume II: Overhaul Steam Turbine Generator – Unit 3  
2 Hydro states at page 4:  
3 *“The study agreed with the 2003 TOOP (HSB) report to extend the major*  
4 *overhaul schedule for the turbine to the nine year frequency but*  
5 *recommended that overhauls on the generators revert back to the six year*  
6 *interval. This specific recommendation will be further reviewed by Hydro*  
7 *before a final decision is made.”*

8 When is a final decision expected to be made by Hydro on the interval frequency  
9 for overhauls on generators?  
10  
11

12 A. Hydro has decided on a six year frequency for overhauls on the generators at  
13 Holyrood. Following completion of the **Overhaul Steam Turbine Generator – Unit 3**  
14 in 2016, the next scheduled overhaul of the Unit 3 generator will be completed in  
15 2022.