

1    Q.    **Tab 6; Volume II: Upgrade Work for Cat Arm, Units 1 and 2**

2            Please explain why Hydro's Asset Management Plan does not require tracking of  
3            maintenance history for spherical valve control systems and deflector servomotors.

4

5

6    A.    The maintenance history for these two assets is generally recorded at a higher level  
7            in the asset hierarchy and would be part of the overall maintenance history for their  
8            larger systems.

9

10           The spherical valve control systems on each unit represent approximately 4% of the  
11           value of the spherical valves system as a whole. The deflector servomotors on each  
12           unit represent approximately 5% of the value of each turbine as a whole. It is not  
13           practical to track maintenance history for small parts of large systems.