

1 Q. Consumer Question: Re: Wind Farms: Is MHI convinced that it is impossible that a  
2 scenario with more than 80 MW of on-island wind generation could result in a lower  
3 CPW than the Isolated Island Scenario?

4  
5 A. MHI's conclusion from its review of Nalcor's work related to wind integration is  
6 contained in section 11 of the MHI report Vol. II. The conclusion that the 80MW limit is  
7 reasonable is in part based on Nalcor's analysis that additional non-dispatchable wind  
8 energy would lead to a higher probability of spill at an increased cost to the system.  
9 Therefore, MHI agrees that the 80MW limitation is a reasonable economic limit.