

1 Q. Consumer Question: Re: Wind Farms: In section 11.3 of Vol. 2 (p. 183), MHI describes  
2 Nalcor's 2004 assessment of the limitations for non-dispatchable generation (exhibit 61),  
3 which recommends an upper limit of 80 MW. MHI provides no analysis or commentary  
4 concerning this study.

5 (a) Why did MHI not comment on or analyze this study?

6 (b) Does it fully endorse the study's methods and conclusions?

7

8 A. As noted in Section 11 of MHI's report Vol. II, MHI did review the aspects of wind  
9 generation as proposed by Nalcor including costs and technical integration limitations.

10

11 MHI's review was sufficient to formulate its conclusion that the 80MW limit was  
12 reasonable for the isolated island alternative, section 11.4 of MHI's report Vol. II.