

1 Q. Consumer Question: In the report, Summary of Newfoundland and Labrador Hydro
2 (NLH) 2010 Long Term Planning Load forecast for the MF Project, Exhibit 27, section
3 5.1.3, p. 16 of 22, Hydro Industrial Load, the energy requirements of the pulp and
4 paper industry are 50% of what they once were because of closures at Stephenville
5 and Grand Falls and the reduction in paper demand at Corner Brook (CB). The
6 ongoing demand forecast for CB is "26 MW in addition to their own significant
7 generation capacity at Deer Lake" (126 MW at Deer Lake). Can Nalcor provide the
8 actual total island system load from CB (include Deer Lake) by year from 2007 to
9 2011?

10

11

12 A. Please see table below of actual electricity consumption for the Corner Brook paper
13 mill as supplied by Deer Lake Power and supplemented by NL Hydro to Corner
14 Brook Pulp and Paper Limited.

Corner Brook Pulp & Paper Energy Requirements	
	(GWh)
2007	1268
2008	1084
2009	920
2010	981
2011	950