

1 Q. Consumer Question: Within Exhibit 101 (Navigant Report) there is a reference to a  
2 CPW of a "low demand profile". NALCOR are requested to provide how this will  
3 impact the cost to the consumer on a kw-hr basis.  
4

5  
6 A. Nalcor interprets this question to refer to the "Low Load Growth" sensitivity  
7 analysis in Exhibit 101, as the phrase "low demand profile" cannot be found in the  
8 report.  
9

10 The analysis requested does not assist consideration of the Reference Question.  
11 Nalcor's analysis for this proceeding is based on system costs over the planning  
12 period, and the Low Load Growth sensitivity analysis indicates a CPW preference for  
13 the Interconnected Island Alternative of \$763 million (2010\$)<sup>1</sup> over the Isolated  
14 Island Alternative.

---

<sup>1</sup> Nalcor's Submission, Table 29 (Revision 1)