

1 Q. Consumer Question: What was the discount rate used in historical economic
2 analysis completed by Newfoundland Hydro for thermal plants.

3

4

5 A. The historical discount rate used by NLH in its *Strategist* generation expansion and
6 cumulative present worth analysis was in the range of 8 to 9 percent on a nominal
7 basis since the year 2000.