

1 Q. Consumer Question: How much of the existing island generating capacity in the
2 west in MWs can be used to fill this 275 MW capacity line?

3

4

5 A. As indicated in Nalcor's response to CA/KPL-Nalcor-189, the new transmission line is
6 required between Bay d'Espoir and Western Avalon to integrate new generation
7 sources west of the Avalon Peninsula in the Isolated Island expansion plan.