

1 Q. Consumer Question: The Interconnected option involves some reliance on the
2 300MW recall provision under the Churchill Falls contract. How much annual
3 energy does Nalcor anticipate using from that recall capacity and does Nalcor's
4 estimated CPW include the foregone revenue from export sales as a cost? What
5 cost does Nalcor use in the CPW for that recall power?

6

7

8 A. The Interconnected Island alternative does not utilize any portion of the 300 MW
9 recall block and it does not factor into the CPW analysis.