

1 Q. Consumer Question: With respect to LIL reliability, it would appear most databases
2 on existing performance of similar assets are done on a per km basis. Is that realistic
3 for LIL, given the long distance involved and the specific climatic conditions?
4

5
6 A. Evaluation of the performance and reliability of long transmission lines, including
7 the Labrador Island Transmission Link, is not generally undertaken on a per
8 kilometre basis, and Nalcor has not used this approach.