

1 Q. The Regional Reliability Organization criterion of one day in 10 years is more
2 stringent than NLH's LOLH of 2.8 hours per year which equates to about one day in
3 every five years. CA/KPL-Nalcor - 012 - Batch 49 RFI Responses of 22 November
4 2011 referred to Section 3.1 of the Nalcor submission where 2.8 LOLH criteria is
5 stated (on a "one day in five years basis") and compared to other more stringent
6 standards. How sensitive is the CPW of the two alternatives to the LOLH criteria?
7 Has Nalcor evaluated the respective changes in CPW as a result of the more
8 stringent and less stringent capacity criteria?

9
10

11 A. Nalcor has not evaluated changes in CPW as a result of changes to these criteria,
12 but has used currently accepted and applied reliability criteria for the Island
13 Interconnected system in its analysis.