

1 Q. With reference to PUB-Nalcor-92, if the present value of energy in 2057 and 2067 is
2 so small why extend the planning period to these dates?

3

4

5 A. The 2010 to 2067 planning period was established based on the long service lives of
6 the assets under study.