

1 Q. The Firm capability for the hydroelectric resource was defined by the most adverse
2 three year sequence of reservoir inflows. Please indicate the anticipated Muskrat
3 Falls generation for the most adverse year of record. Please describe the portion of
4 FIRM energy attributable to Churchill Falls.

5

6

7 A. Nalcor understands this question to be in the context of the following statement in
8 Nalcor's Submission:

9 Firm capability for the hydroelectric resources is the firm energy
10 capability of those resources under the most adverse three-year
11 sequence of reservoir inflows occurring within the historical record.¹

12

13 The definition of firm energy used for Nalcor's and NL Hydro's modeling is
14 consistent with this definition:

15 The definition of firm energy used for this study is the maximum
16 average energy that can be produced during the most severe dry
17 sequence of the hydrological record. The dry sequence begins after
18 the last period when secondary energy was generated and ends
19 when the reservoirs are just empty.²

20

21 or this very similar version:

22 The value of firm is specifically determined based on the critical
23 hydrologic period which covers a sequential set of years defined by
24 the seasonal reservoir (Smallwood) being at full supply level (FSL) at

¹ Nalcor's Submission, page 30

² CE-28 (Public) Revision 1, page 34

1 the beginning of the critical period and at Low Supply Level (LSL) at
2 the end of the period.³

3
4 When the Island system's production is evaluated against this definition, the
5 critical sequence is three years in duration. This three year duration is the
6 result of application of the definition, not the definition itself.

7 Production during the "most adverse year of record" is represented by the
8 annual production at the end of the critical hydrological period, and
9 therefore the value of 4.47 TWh/year⁴, as reported in Exhibit CE-27 Rev. 1
10 (Public), accurately represents, in Nalcor's view, Muskrat Falls' firm
11 production.

12
13 Please note Nalcor's latest modeling⁵ includes both the Churchill Falls and
14 Muskrat Falls facilities and reservoirs, and Churchill Falls production has
15 been based on the terms of the Hydro Quebec Power Contract that will be in
16 effect when Muskrat Falls is in service. More specifically, Nalcor's power
17 and energy modeling assumes that Churchill Falls will be receiving
18 Continuous Energy, as defined in Schedule III, Article 1.1 (II) of the Hydro
19 Quebec power contract⁶.

20
21 "Continuous Energy" means, in respect of any month, the
22 number of kilowatt hours obtainable, calculated to the
23 nearest 1/100 of a billion kilowatt-hours, when the Annual
24 Energy Base is multiplied by the number which corresponds

³ CE-21, page 11

⁴ Exhibit CE-27 Rev. 1 (Public), page 3

⁵ as represented in Confidential Exhibit CE-21

⁶ <http://www.pub.nl.ca/applications/Nalcor2009Water/files/applic/Application-Volumell-Revised.pdf>, pg. 99

1 to the number of days in the month concerned and the result
2 is then divided by the number which corresponds to the
3 number of days in the year concerned.

4
5 Under these conditions, Churchill Falls monthly production is
6 approximately constant.

7
8 Analysis by Hatch indicates the critical period to be from 1984 to 1996 in the
9 50 year record used for analysis. The inflows can be found in CE-28, Rev. 1
10 (Public), beginning at page 73. Analysis contained in Confidential Exhibit CE-
11 21 indicates firm production from CF over this critical period to be
12 approximately 4,170 MW.

13
14 The tailrace flow at Churchill Falls corresponding to this rating is
15 approximately 1,450 m³/s.

16
17 Based on this outflow over the critical period, the contribution from
18 Churchill Falls would be as follows:

Year	Churchill Falls Flow (m ³ /s) (Note 1)	Gull Island Local Inflow (m ³ /s) (Note 2)	Muskrat Falls Local Inflow (m ³ /s) (Note 3)	Total Flow at Muskrat Falls (m ³ /s)	% From Churchill Falls
1984	1450.0	390.9	64.2	1905.1	76.1
1985	1450.0	373.3	61.3	1884.5	76.9
1986	1450.0	364.2	59.8	1874.0	77.4
1987	1450.0	370.6	60.8	1881.5	77.1
1988	1450.0	390.2	64.0	1904.2	76.1
1989	1450.0	306.2	50.2	1806.5	80.3
1990	1450.0	163.8	26.9	1640.7	88.4
1991	1450.0	294.8	48.4	1793.2	80.9
1992	1450.0	348.5	57.2	1855.6	78.1
1993	1450.0	375.6	61.6	1887.2	76.8
1994	1450.0	412.9	67.8	1930.7	75.1
1995	1450.0	331.3	54.4	1835.6	79.0
1996	1450.0	369.4	60.6	1880.0	77.1

1 Note 1: Churchill Falls flow estimated based on 4,170 MW firm output as per CE-21.

2 Note 2: as per CE-28 Rev. 1 (Public) page 79

3 Note 3: as per CE-28 Rev. 1 (Public) page 80