

1 Q. How were decommissioning costs for Holyrood developed? Where are the costs  
2 captured in the CPWDetails document? Do the decommissioning costs include  
3 asbestos removal and site remediation?  
4  
5

6 A. The decommissioning costs for Holyrood are included in HRD DCL1 and HRD DCL2.  
7 Please see MHI-Nalcor-105 for more detail.  
8

9 The costs are captured in the “Fixed Charges” section of the CE-39 MHI-Nalcor-1  
10 CPWDetails document.  
11

12 Given the high level nature of the estimates, the costs associated with any asbestos  
13 removal have not been fully assessed within the context of site remediation.  
14 However, virtually all the asbestos at Holyrood was removed during the 2005-2007  
15 asbestos removal program. The relatively low amount remaining is being managed  
16 through the Holyrood Asbestos Management Plan (AMP).  
17

18 As noted in MHI-Nalcor-105, some site remediation is included in the estimates, but  
19 again, given the high level nature of the estimates, the total amount included in the  
20 estimates for remediation cannot be confirmed. It should be noted that as Hydro  
21 would still be using the site, the site as a whole would not be remediated.