

1 Q. As one unit at Holyrood is already capable of synchronous condenser operation;  
2 when are the other two units converted? Please provide a document that outlines  
3 the plan and timing for the synchronous condenser conversion at Holyrood.

4

5

6 A. While no specific document has been prepared for the plan and timing of the  
7 conversion of the remaining two units to synchronous condensers at Holyrood, it is  
8 anticipated that conversion must be completed prior to commissioning the Soldiers  
9 Pond converter. It has recently been decided that SNC-L will perform the  
10 engineering and procurement activities associated with these conversions and as  
11 part of that task a schedule and execution plan will be developed in conjunction  
12 with the system planning and operations teams.